



WESAM SYSTEMS

**Thermal Inspection for Electrical Equipment  
Using Advanced FLIR E60bx Thermal Camera**

**For**



**Customer:\*\*\*\*\***


**Location:\*\*\*\*\***

**2/3-5/2015**

**By**

**Engr. Adrian Arigo  
ITC Level 1 Thermographer**



 WESAM SYSTEMS	<b>Thermography Inspection for Electrical Equipment at *****</b>	<b>Date: 2/3-5/2015</b>
---	--	-----------------------------

Inspection Site Information	
<b>Customer</b>	*****
<b>Address</b>	*****
<b>Contact Person</b>	*****
<b>Mobile</b>	*****
<b>Email</b>	*****
<b>Thermographer</b>	Engr. Ahmed Abu Al-Khair
<b>Phone number</b>	+966500463798
<b>E-mail address</b>	abu.alkhair@wesams.com

**Tool used for the service:**

Using Advanced FLIR E60bx Thermal Camera

**Engineer's Qualifications:**

Engr. Adrian Arigo, ITC Level 1 Thermographer

**Contact Details:**

WESAM SYSTEMS Co. Ltd  
Office # 803, Al-Jarbou Tower, Custodian of the  
Two Holy Mosques Rd., Al Aqrabiyah, Al-  
Khobar, Saudi Arabia

Phone: 0133616126


Email: [info@wasamsys.com](mailto:info@wasamsys.com)


**Overview of Fault Rating:**

<b>0:</b> Normal	Temp rise 0-5 °C	No action
<b>1:</b> Low grade	Temp rise 5.1-10 °C	To be monitored – Plan new inspection
<b>2:</b> Medium grade	Temp rise 10.1-35.1 °C	Repair at scheduled shut down
<b>3:</b> High	Temp rise >35.1 °C	Repair immediately

 WESAM SYSTEMS	<b>Thermography Inspection for Electrical Equipment at *****</b>	<b>Date: 2/3-5/2015</b>
---	--	-----------------------------


Summary of Findings				
Location	Equipment	Fault	Recommendation	Page Number
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	4
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	5
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	6
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	7
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	8
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	9
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	10
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Medium Grade	Repair at schedule shutdown	11
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	12
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	13
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	14
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	15
Chiller Pump Room Roof – Main Building	AGH0187/EP/EMCC-2	Normal	No Action	16

<b>Infrared Thermogram 2/04/2015</b>		<b>Location</b> Chiller Pump Room, Roof – Main Building
		<b>Equipment</b> AGH0187/EP/EMCC-2
<b>Image File Name</b> FLIR0288.jpg		<b>Image Date</b> 2/04/2015
<b>Image Time</b> 10:35:24		
<b>Ar1 Max. Temperature</b> 41.1 °C		

<b>Photo and Identification</b>	<b>Severity Rating &amp; Recommendation</b>		
	1 Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2 Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>	
3 High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>	
<b>Analysis:</b>			
Temperature analysis is normal			

<b>Corrective action:</b>	
Recommendation: Nothing to do since the temperature reading was normal	
In maximum load, this main circuit breaker (Ar1 in thermal image above shown) model reference temperature should not exceed 70 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).	


<b>Inspected &amp; Reported by :</b>	Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015		
Repaired by: .....	date:		
Comment:.....			

**Infrared Thermogram 2/04/2015**


Location	Chiller Pump Room, Roof – Main Building
Equipment	AGH0187/EP/EMCC-2

Image File Name	FLIR0289.jpg
Image Date	2/04/2015
Image Time	10:36:21

Ar1 Max. Temperature	38.2 °C
Ar2 Max. Temperature	39.6 °C
Ar3 Max. Temperature	38.0 °C
Dt1 Value	1.60 °C

**Photo and Identification**


Severity Rating & Recommendation			
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

**Analysis:**

Temperature analysis is normal

**Corrective action:**

Recommendation: Nothing to do since the temperature reading was normal

In maximum load, these connections and terminations (Ar1, Ar2 and Ar3 in thermal image above shown) model reference temperature should not exceed  $90^{\circ}\text{C}$  (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: .....

date:

Comment:.....




WESAM SYSTEMS

# Thermography Inspection for Electrical Equipment at

\*\*\*\*\*

Date:  
2/3-5/2015

## Infrared Thermogram 2/04/2015




Location Chiller Pump Room, Roof – Main Building  
Equipment AGH0187/EP/EMCC-2

Image File Name	FLIR0291.jpg
Image Date	2/04/2015
Image Time	10:37:26

Ar1 Max. Temperature	51.8 °C
Ar2 Max. Temperature	53.8 °C
Ar3 Max. Temperature	51.5 °C
Dt1 Value	2.30 °C

## Photo and Identification



## Severity Rating & Recommendation

1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

## Analysis:

Temperature analysis is normal

## Corrective action:

Recommendation: Nothing to do since the temperature reading was normal

In maximum load, these connections and terminations (Ar1, Ar2 and Ar3 in thermal image above shown) model reference temperature should not exceed 90 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).


**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015


Repaired by: .....


date:

Comment:.....



 <p>WESAM SYSTEMS</p>	<p align="center"><b>Thermography Inspection for Electrical Equipment</b> at *****</p>	<p align="center"><b>Date:</b> <b>2/3-5/2015</b></p>
---	--	--

<p><b>Infrared Thermogram 2/04/2015</b></p> 	<table border="1"> <tr> <td>Location</td> <td>Chiller Pump Room, Roof – Main Building</td> </tr> <tr> <td>Equipment</td> <td>AGH0187/EP/EMCC-2</td> </tr> </table> <table border="1"> <tr> <td>Image File Name</td> <td>FLIR0294.jpg</td> </tr> <tr> <td>Image Date</td> <td>2/04/2015</td> </tr> <tr> <td>Image Time</td> <td>10:39:49</td> </tr> </table> <table border="1"> <tr> <td>Ar1 Max. Temperature</td> <td>42.3 °C</td> </tr> </table>	Location	Chiller Pump Room, Roof – Main Building	Equipment	AGH0187/EP/EMCC-2	Image File Name	FLIR0294.jpg	Image Date	2/04/2015	Image Time	10:39:49	Ar1 Max. Temperature	42.3 °C
Location	Chiller Pump Room, Roof – Main Building												
Equipment	AGH0187/EP/EMCC-2												
Image File Name	FLIR0294.jpg												
Image Date	2/04/2015												
Image Time	10:39:49												
Ar1 Max. Temperature	42.3 °C												

<p><b>Photo and Identification</b></p> 	<table border="1"> <tr> <th colspan="4">Severity Rating &amp; Recommendation</th> </tr> <tr> <td>1</td> <td>Low (<math>\Delta = 5.1-10^{\circ}\text{C}</math>)</td> <td>To be monitored</td> <td><input type="checkbox"/></td> </tr> <tr> <td>2</td> <td>Medium (<math>\Delta = 10.1-35^{\circ}\text{C}</math>)</td> <td>Repair as soon as schedule permits</td> <td><input type="checkbox"/></td> </tr> <tr> <td>3</td> <td>High (<math>\Delta &gt; 35.1^{\circ}\text{C}</math>)</td> <td>Repair immediately</td> <td><input type="checkbox"/></td> </tr> </table> <p><b>Analysis:</b></p> <p>Temperature analysis is normal</p>	Severity Rating & Recommendation				1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>	2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>	3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>
Severity Rating & Recommendation																	
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>														
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>														
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>														

**Corrective action:**


Recommendation: Nothing to do since the temperature reading was normal


In maximum load, this main circuit breaker (Ar1 in thermal image above shown) model reference temperature should not exceed 70 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: ..... date:

Comment:.....



<b>Photo and Identification</b>		<b>Severity Rating &amp; Recommendation</b>			
		1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
		2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
		3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>
<b>Analysis:</b>					
Temperature analysis is normal					

**Corrective action:**

Recommendation: Nothing to do since the temperature reading was normal


In maximum load, these connections and terminations (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed 90 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date: **2/3-5/2015**

Repaired by: ..... date:

Comment:.....



**Infrared Thermogram 2/04/2015**


<b>Location</b>	Chiller Pump Room, Roof – Main Building
<b>Equipment</b>	AGH0187/EP/EMCC-2

Image File Name	FLIR0298.jpg
Image Date	2/04/2015
Image Time	10:43:26

Ar1 Max. Temperature	58.2 °C
Ar2 Max. Temperature	60.4 °C
Ar3 Max. Temperature	57.9 °C
Dt1 Value	2.50 °C

**Photo and Identification**


Severity Rating & Recommendation			
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

**Analysis:**

Temperature analysis is normal

**Corrective action:**

Recommendation: Nothing to do since the temperature reading was normal


In maximum load, these connections and terminations (Ar1, Ar2 and Ar3 in thermal image above shown) model reference temperature should not exceed 90 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: .....

date:


Comment:.....

**Infrared Thermogram 2/04/2015**


Location	Chiller Pump Room, Roof – Main Building
Equipment	AGH0187/EP/EMCC-2

Image File Name	FLIR0301.jpg
Image Date	2/04/2015
Image Time	10:45:19

Ar1 Max. Temperature	57.3 °C
Ar2 Max. Temperature	59.7 °C
Dt1 Value	2.40 °C

**Photo and Identification**


Severity Rating & Recommendation			
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

**Analysis:**

Temperature analysis is normal

**Corrective action:**

Recommendation: Nothing to do since the temperature reading was normal

In maximum load, these circuit breakers (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed 70 °C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: .....

date:

Comment:.....




WESAM SYSTEMS

# Thermography Inspection for Electrical Equipment at

\*\*\*\*\*

Date:  
2/3-5/2015

## Infrared Thermogram 2/04/2015




Location Chiller Pump Room, Roof – Main Building  
Equipment AGH0187/EP/EMCC-2

Image File Name	FLIR0303.jpg
Image Date	2/04/2015
Image Time	10:46:50

Ar1 Max. Temperature	58.0 °C
Ar2 Max. Temperature	68.5 °C
Dt1 Value	10.5 °C

## Photo and Identification



## Severity Rating & Recommendation

1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input checked="" type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

## Analysis:

The 50mm<sup>2</sup> size of wire was overloaded (actual load in line 2 phase was 150 amperes) (Ar2 in thermal image above shown)

## Corrective action:

Recommendation: Replace the existing cables (Ar2 in thermal image above shown) with higher ampacity rating as necessary, (Re-termination is required, then investigate -kindly double check the balancing of load / load – torque in each line side of the cables and do another thermal inspection is needed after repair)

In maximum load, these connections and terminations (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed 90 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).


**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: .....

date:

Comment:.....

**Infrared Thermogram 2/04/2015**



Location Chiller Pump Room, Roof – Main Building  
Equipment AGH0187/EP/EMCC-2

Image File Name	FLIR0313.jpg
Image Date	2/04/2015
Image Time	10:57:22

Ar1 Max. Temperature	55.0 °C
Ar2 Max. Temperature	55.7 °C
Dt1 Value	0.70 °C

**Photo and Identification**



**Severity Rating & Recommendation**

1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

**Analysis:**

Temperature analysis is normal

**Corrective action:**

Recommendation: Nothing to do since the temperature reading was normal

In maximum load, these connections and terminations (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed 90 ° C (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: .....

date:

Comment:.....






WESAM SYSTEMS

# Thermography Inspection for Electrical Equipment at

\*\*\*\*\*

Date:  
2/3-5/2015

## Infrared Thermogram 2/04/2015




Location Chiller Pump Room, Roof – Main Building  
Equipment AGH0187/EP/EMCC-2

Image File Name	FLIR0320.jpg
Image Date	2/04/2015
Image Time	11:01:43

Ar1 Max. Temperature	48.5 °C
Ar2 Max. Temperature	44.2 °C
Dt1 Value	4.30 °C

## Photo and Identification



## Severity Rating & Recommendation

1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

## Analysis:

Temperature analysis is normal

## Corrective action:

Recommendation: Nothing to do since the temperature reading was normal


In maximum load, these contactors (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed  $90^{\circ}\text{C}$  (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).


**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015


Repaired by: .....

date:

Comment:.....

 WESAM SYSTEMS	<b>Thermography Inspection for Electrical Equipment</b> <b>at</b> *****	<b>Date:</b> <b>2/3-5/2015</b>
---	---	-----------------------------------


<b>Infrared Thermogram 2/04/2015</b> 		<table border="1"> <tr> <td>Location</td><td>Chiller Pump Room, Roof – Main Building</td></tr> <tr> <td>Equipment</td><td>AGH0187/EP/EMCC-2</td></tr> </table> <table border="1"> <tr> <td>Image File Name</td><td>FLIR0323.jpg</td></tr> <tr> <td>Image Date</td><td>2/04/2015</td></tr> <tr> <td>Image Time</td><td>11:02:46</td></tr> </table> <table border="1"> <tr> <td>Ar1 Max. Temperature</td><td>52.6 °C</td></tr> <tr> <td>Ar2 Max. Temperature</td><td>47.9 °C</td></tr> <tr> <td>Dt1 Value</td><td>4.70 °C</td></tr> </table>		Location	Chiller Pump Room, Roof – Main Building	Equipment	AGH0187/EP/EMCC-2	Image File Name	FLIR0323.jpg	Image Date	2/04/2015	Image Time	11:02:46	Ar1 Max. Temperature	52.6 °C	Ar2 Max. Temperature	47.9 °C	Dt1 Value	4.70 °C
Location	Chiller Pump Room, Roof – Main Building																		
Equipment	AGH0187/EP/EMCC-2																		
Image File Name	FLIR0323.jpg																		
Image Date	2/04/2015																		
Image Time	11:02:46																		
Ar1 Max. Temperature	52.6 °C																		
Ar2 Max. Temperature	47.9 °C																		
Dt1 Value	4.70 °C																		


<b>Photo and Identification</b> 		<table border="1"> <tr> <th colspan="4">Severity Rating &amp; Recommendation</th></tr> <tr> <td>1</td><td>Low (<math>\Delta = 5.1-10^{\circ}\text{C}</math>)</td><td>To be monitored</td><td><input type="checkbox"/></td></tr> <tr> <td>2</td><td>Medium (<math>\Delta = 10.1-35^{\circ}\text{C}</math>)</td><td>Repair as soon as schedule permits</td><td><input type="checkbox"/></td></tr> <tr> <td>3</td><td>High (<math>\Delta &gt; 35.1^{\circ}\text{C}</math>)</td><td>Repair immediately</td><td><input type="checkbox"/></td></tr> </table> <b>Analysis:</b> Temperature analysis is normal		Severity Rating & Recommendation				1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>	2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>	3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>
Severity Rating & Recommendation																			
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>																
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>																
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>																


<b>Corrective action:</b> <p>Recommendation: Nothing to do since the temperature reading was normal</p> <p>In maximum load, these contactors (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed <math>90^{\circ}\text{C}</math> (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).</p>	
--	--

<b>Inspected &amp; Reported by :</b> Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015 Repaired by: ..... date: Comment:.....	
--	--




 WESAM SYSTEMS	<b>Thermography Inspection for Electrical Equipment</b> <b>at</b> *****	<b>Date:</b> <b>2/3-5/2015</b>
---	---	-----------------------------------

<b>Infrared Thermogram 2/04/2015</b> 	<table border="1"> <tr> <td><b>Location</b></td> <td>Chiller Pump Room, Roof – Main Building</td> </tr> <tr> <td><b>Equipment</b></td> <td>AGH0187/EP/EMCC-2</td> </tr> </table> <table border="1"> <tr> <td>Image File Name</td> <td>FLIR0328.jpg</td> </tr> <tr> <td>Image Date</td> <td>2/04/2015</td> </tr> <tr> <td>Image Time</td> <td>11:06:19</td> </tr> </table> <table border="1"> <tr> <td>Ar1 Max. Temperature</td> <td>58.9 °C</td> </tr> </table>	<b>Location</b>	Chiller Pump Room, Roof – Main Building	<b>Equipment</b>	AGH0187/EP/EMCC-2	Image File Name	FLIR0328.jpg	Image Date	2/04/2015	Image Time	11:06:19	Ar1 Max. Temperature	58.9 °C
<b>Location</b>	Chiller Pump Room, Roof – Main Building												
<b>Equipment</b>	AGH0187/EP/EMCC-2												
Image File Name	FLIR0328.jpg												
Image Date	2/04/2015												
Image Time	11:06:19												
Ar1 Max. Temperature	58.9 °C												

<b>Photo and Identification</b> 	<table border="1"> <tr> <th colspan="4">Severity Rating &amp; Recommendation</th> </tr> <tr> <td>1</td> <td>Low (<math>\Delta = 5.1-10^{\circ}\text{C}</math>)</td> <td>To be monitored</td> <td><input type="checkbox"/></td> </tr> <tr> <td>2</td> <td>Medium (<math>\Delta = 10.1-35^{\circ}\text{C}</math>)</td> <td>Repair as soon as schedule permits</td> <td><input type="checkbox"/></td> </tr> <tr> <td>3</td> <td>High (<math>\Delta &gt; 35.1^{\circ}\text{C}</math>)</td> <td>Repair immediately</td> <td><input type="checkbox"/></td> </tr> </table> <b>Analysis:</b> Temperature analysis is normal	Severity Rating & Recommendation				1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>	2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>	3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>
Severity Rating & Recommendation																	
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>														
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>														
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>														

<b>Corrective action:</b> <p>Recommendation: Nothing to do since the temperature reading was normal</p> <p>In maximum load, this relay (Ar1 in thermal image above shown) model reference temperature should not exceed 55 °C.</p>
---


<b>Inspected &amp; Reported by :</b> Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015 Repaired by: ..... date: Comment:.....
--

**Infrared Thermogram 2/04/2015**


Location	Chiller Pump Room, Roof – Main Building
Equipment	AGH0187/EP/EMCC-2

Image File Name	FLIR0331.jpg
Image Date	2/04/2015
Image Time	11:07:31

Ar1 Max. Temperature	42.5 °C
Ar2 Max. Temperature	40.1 °C
Dt1 Value	2.40 °C

**Photo and Identification**


Severity Rating & Recommendation			
1	Low ( $\Delta = 5.1-10^{\circ}\text{C}$ )	To be monitored	<input type="checkbox"/>
2	Medium ( $\Delta = 10.1-35^{\circ}\text{C}$ )	Repair as soon as schedule permits	<input type="checkbox"/>
3	High ( $\Delta > 35.1^{\circ}\text{C}$ )	Repair immediately	<input type="checkbox"/>

**Analysis:**

Temperature analysis is normal

**Corrective action:**

Recommendation: Nothing to do since the temperature reading was normal

In maximum load, these connections and terminations (Ar1 and Ar2 in thermal image above shown) model reference temperature should not exceed  $90^{\circ}\text{C}$  (reference Standard for Infrared Inspection of Electrical System and Rotating Equipment).

**Inspected & Reported by :** Engr. Ahmed Abu Al-Khair / Engr. Adrian Arigo Signature:.....date:2/3-5/2015

Repaired by: .....

date:

Comment:.....